

Annual Drinking Water Quality Report for 2020
Village of Bainbridge
33 West Main Street
Bainbridge, NY 13733
(Public Water Supply ID#NY0801739)

INTRODUCTION

To comply with State regulations, the Village of Bainbridge, annually issues a report describing the quality of your drinking water. The purpose of this report is to raise your understanding of drinking water and awareness of the need to protect our drinking water sources. We are proud to report that our system did not violate any maximum contaminant levels or action level standards. This report provides an overview of last year's water quality. Included are details about where your water comes from, what it contains, and how it compares to State standards.

If you have any questions about this report, or concerning your drinking water, please contact **Jeff Webb, Superintendent of the Department of Public Works, at 607-967-8696**. We want you to be informed about your drinking water. If you want to learn more, please attend any of our regularly scheduled village board meetings. The meetings are held the third Tuesday of each month at 6:30 PM in the Village Clerk's Office, 33 West Main Street, Bainbridge.

WHERE DOES OUR WATER COME FROM?

In general, the sources of drinking water (both tap water and bottled water) include rivers, lakes, streams, ponds, reservoirs, springs, and wells. As water travels over the surface of the land or through the ground, it dissolves naturally occurring minerals and, in some cases, radioactive material, it may also pick up substances resulting from the presence of animals or from human activities. Contaminants that may be present in source water include: microbial contaminants; inorganic contaminants; pesticides and herbicides; organic chemical contaminants; and radioactive contaminants. In order to ensure that tap water is safe to drink, the State and the EPA prescribe regulations which limit the amount of certain contaminants in water provided by public water systems. The State Health Department's and the FDA's regulations establish limits for contaminants in bottled water which must provide the same protection for public health.

Our water system serves approximately 1600 people through 600 service connections. Our water sources are two 200 foot deep drilled ground water wells which are located within the village limits on parcels of land owned by the village. Well #2 is the primary water source for the Village of Bainbridge. Well #1 is used as an emergency/backup source. Water is pumped from the wells into the Water Treatment Plant where it is treated with NSF approved liquid Sodium Hypochlorite solution (bleach) for disinfection. The treated water then flows into the distribution system and is stored at our storage facility consisting of two 326,000 gallon steel tanks.

ARE THERE CONTAMINANTS IN OUR DRINKING WATER?

As State regulations require, we routinely test your drinking water for numerous contaminants. These contaminants include: total coliform, inorganic compounds, nitrate, nitrite, lead and copper, volatile organic compounds, total trihalomethanes, haloacetic acids, radiological and synthetic organic compounds. The table presented below depicts which compounds were detected in your drinking water. The State allows us to test for some contaminants less than once per year because the concentrations of these contaminants do not change frequently. **Some of our data, though representative, are more than one year old.**

It should be noted that all drinking water, including bottled drinking water, may be reasonably expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the EPA's Safe Drinking Water Hotline (800-426-4791) or the Chenango County Health Department at (607) 337-1673.

| Table of Detected Contaminants | | | | | | | |
|--------------------------------|------------------|----------------|---|------------------|------|----------------------------------|---|
| Contaminate | Violation Yes/No | Date of Sample | Level Detected (Range) | Unit Measurement | MCLG | Regulatory Limit (MCL, TT or AL) | Likely Source of Contamination |
| Inorganic Contaminants | | | | | | | |
| Nitrate Well #1 | No | 10/21/20 | 1.1 | mg/L | 10 | MCL = 10 | Runoff from fertilizer use; Leaching from septic tanks, sewage; Erosion of natural deposits. |
| Nitrate Well #2 | No | 05/06/20 | 0.65 | mg/L | 10 | MCL = 10 | Runoff from fertilizer use; Leaching from septic tanks, sewage; Erosion of natural deposits. |
| Lead | No | 9/19 | <0.0010 ¹ (<0.0010- <0.0010) | mg/L | 0 | AL= 0.015 | Corrosion of household plumbing systems; Erosion of natural deposits. |
| Copper | No | 9/19 | 0.0076 ² (0.019- 0.100) | mg/L | 1.3 | AL= 1.3 | Corrosion of household plumbing systems; Erosion of natural deposits; leaching from wood preservatives. |
| Barium Well #1 | No | 1/22/19 | 88.0 | ug/L | 2 | MCL = 2 | Discharge of drilling wastes; Discharge from metal refineries; Erosion of natural deposits. |
| Barium Well #2 | No | 1/22/19 | 148.0 | ug/L | 2 | MCL = 2 | Discharge of drilling wastes; Discharge from metal refineries; Erosion of natural deposits. |
| Arsenic Well #2 | No | 1/22/19 | 1.2 | ug/L | n/a | 10 | Erosion of natural deposits; run-off from orchards; run-off from glass and electronics production wastes. |
| Asbestos | No | 7/31/19 | 0.69 | MFL | 7 | 7 | Decay of cement water mains; Erosion of natural deposits. |

| Table of Detected Contaminants | | | | | | | |
|-------------------------------------|------------------|----------------|------------------------|------------------|------|----------------------------------|--|
| Contaminant | Violation Yes/No | Date of Sample | Level Detected (Range) | Unit Measurement | MCLG | Regulatory Limit (MCL, TT or AL) | Likely Source of Contamination |
| Primary Organic Contaminants | | | | | | | |
| Toluene Well #2 | No | 7/25/18 | 2.4 | ug/L | n/a | MCL=5 | Leaks from gasoline tanks; Discharge from petroleum factories. Leaching of solvent from lining of potable water tanks. |
| a | | | | | | | |
| Disinfection Byproducts | | | | | | | |
| Total Tri-Halomethanes (LRAA1) | No | 7/22/2020 | 5.3 | µg/L | n/a | MCL = 80 | By-product of drinking water chlorination needed to kill harmful organisms. TTHMs are formed when source water contains large amounts of organic matter. |
| Total Tri-Halomethanes (LRAA2) | No | 7/22/2020 | <2.0 | µg/L | n/a | | |
| Haloacetic Acids (LRAA1) | No | 7/22/2020 | 3.6 | µg/L | n/a | MCL = 60 | By-product of drinking water chlorination needed to kill harmful organisms. |
| Haloacetic Acids (LRAA2) | No | 7/22/2020 | <2.0 | µg/L | n/a | | |

Definitions:

Maximum Contaminant Level (MCL): The highest level of a contaminant that is allowed in drinking water. MCLs are set as close to the MCLGs as feasible.

Maximum Contaminant Level Goal (MCLG): The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs allow for a margin of safety.

Action Level (AL): The concentration of a contaminant which, if exceeded, triggers treatment or other requirements which a water system must follow.

Treatment Technique (TT): A required process intended to reduce the level of a contaminant in drinking water.

Non-Detects (ND): Laboratory analysis indicates that the constituent is not present.

Milligrams per liter (mg/l): Corresponds to one part of liquid in one million parts of liquid (parts per million - ppm).

Micrograms per liter (ug/l): Corresponds to one part of liquid in one billion parts of liquid (parts per billion - ppb).

Nanograms per liter (ng/l): Corresponds to one part of liquid to one trillion parts of liquid (parts per trillion - ppt).

Picograms per liter (pg/l): Corresponds to one part per of liquid to one quadrillion parts of liquid (parts per quadrillion – ppq).

Picocuries per liter (pCi/L): A measure of the radioactivity in water.

Millirems per year (mrem/yr): A measure of radiation absorbed by the body.

Million Fibers per Liter (MFL): A measure of the presence of asbestos fibers that are longer than 10 micrometers.

WHAT DOES THIS INFORMATION MEAN?

As you can see by the table, our system had no MCL or AL exceedances for contaminants. We have learned through our testing that some contaminants have been detected; however, these contaminants were detected below the level allowed by the State.

IS OUR WATER SYSTEM MEETING OTHER RULES THAT GOVERN OPERATIONS?

During 2020 our system was in compliance with applicable State drinking water operating, monitoring, and reporting requirements.

DO I NEED TO TAKE SPECIAL PRECAUTIONS?

Although our drinking water met or exceeded state and federal regulations, some people may be more vulnerable to disease causing microorganisms or pathogens in drinking water than the general population. Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice from their health care provider about their drinking water. EPA/CDC guidelines on appropriate means to lessen the risk of infection by Cryptosporidium, Giardia and other microbial pathogens are available from the Safe Drinking Water Hotline (800-426-4791).

WHY SAVE WATER AND HOW TO AVOID WASTING IT?

Although our system has an adequate amount of water to meet present and future demands, there are a number of reasons why it is important to conserve water:

- ◆ Saving water saves energy and some of the costs associated with both of these necessities of life;
- ◆ Saving water reduces the cost of energy required to pump water and the need to construct costly new wells, pumping systems and water towers; and
- ◆ Saving water lessens the strain on the water system during a dry spell or drought, helping to avoid severe water use restrictions so that essential fire fighting needs are met.

You can play a role in conserving water by becoming conscious of the amount of water your household is using, and by looking for ways to use less whenever you can. It is not hard to conserve water.

Conservation tips include:

- ◆ Automatic dishwashers use 15 gallons for every cycle, regardless of how many dishes are loaded. So get a run for your money and load it to capacity.
- ◆ Turn off the tap when brushing your teeth.
- ◆ Check every faucet in your home for leaks. Just a slow drip can waste 15 to 20 gallons a day. Fix it and you can save almost 6,000 gallons per year.
- ◆ Check your toilets for leaks by putting a few drops of food coloring in the tank, watch for a few minutes to see if the color shows up in the bowl. It is not uncommon to lose up to 100 gallons a day from an invisible toilet leak. Fix it and you save more than 30,000 gallons a year.

CLOSING

Thank you for allowing us to continue to provide your family with quality drinking water this year. In order to maintain a safe and dependable water supply we sometimes need to make improvements that will benefit all of our customers. The costs of these improvements may be reflected in the rate structure. Rate adjustments may be necessary in order to address these improvements. We ask that all our customers help us protect our water sources, which are the heart of our community. Please call our office if you have questions.